

Stormwater Quality Monitoring Data

Environmental Protection Licence No: 13181	Samples Collected: 13 April 2016
---	----------------------------------

	Units	EPL Criteria	Monitoring Pit 1**	Monitoring Pit 2**	Monitoring Pit 3**	Monitoring Pit 4
pH		6.5 – 8.5	-	-	-	6.93
Total Nitrogen as N	mg/L	10	-	-	-	1.3
Oil and Grease	mg/L	10	-	-	-	<5
Reactive Phosphorous	mg/L	*	-	-	-	0.07
Total Suspended Solids	mg/L	50	-	-	-	21

*no monitoring criteria for Reactive Phosphorus parameter

**stormwater shut off valves were closed due to fuel vessel operations at the berth therefore no discharge during this rain event.