

Stormwater Quality Monitoring Data

Environmental Protection Licence No: 13181	Samples Collected: 4/6 June 2016
---	----------------------------------

	Units	EPL Criteria	Monitoring Pit 1	Monitoring Pit 2	Monitoring Pit 3	Monitoring Pit 4
pH		6.5 – 8.5	7.11	7.16	7.26	6.98
Total Nitrogen as N	mg/L	10	0.23	0.22	0.14	0.98
Oil and Grease	mg/L	10	18	<5	<5	<5
Reactive Phosphorous	mg/L	*	0.05	0.07	0.07	0.12
Total Suspended Solids	mg/L	50	21	<5	<5	29

*no monitoring criteria for Reactive Phosphorus parameter