

Mayfield Concept Plan Approval

Quarterly Stormwater Monitoring Report

March 2022 to May 2022

Date of sampling: 3 March 2022

Date Published: 20 April 2022

In accordance with Schedule 3 Condition 2.21 (d) of the Mayfield Concept Approval, PON has developed a Stormwater Management Strategy for the site.

To support the strategy PON conducts an ongoing site wide monitoring program to confirm that the site continues to meet the commitments and requirements of the Concept Plan Approval. Sampling is undertaken on a quarterly basis at the downstream extent of the site drainage infrastructure prior to discharge into the Eastern and Western drains. There are a total of six sampling locations. Please refer to Figure 1 below.

Figure 1: Mayfield Site Water Quality Monitoring Locations



Analytes that are to be monitored at each sample location are detailed in Table 1 below.

Table 1: Analytes for Stormwater

Pollutant	Unit of Measure	Frequency	Sampling Method
Total suspended solids	mg/L	Quarterly	Grab sample during rainfall event
pH	pH units	Quarterly	Grab sample during rainfall event
Nitrogen (total)	ug/L	Quarterly	Grab sample during rainfall event
Oil and grease	mg/L	Quarterly	Grab sample during rainfall event
Phosphate	ug/L	Quarterly	Grab sample during rainfall event
BOD	mg/L	Quarterly	Grab sample during rainfall event
Dissolved oxygen	%	Quarterly	Grab sample during rainfall event
Heavy metals (comprehensive suite)	ug/L	Annually	Grab sample during rainfall event

Stormwater sampling was conducted on 3 March 2022. This round included all analytes required to be monitored quarterly, the results are presented below in Table 2.

The comprehensive heavy metal suite that are required to be monitored annually was conducted previously in October 2021.

Table 2: Results for quarterly suite of analytes

3 March 2022	Units	ED1	ED2	ED3	WD1	WD2	WD3
pH	pH unit	6.94	7	6.94	6.77	6.86	6.94
TSS	mg/L	5	7	<5	6	7	<5
Dissolved Oxygen	%	89	64	54	62	50	51
Total Nitrogen (calc)	µg/L	400	500	500	600	900	700
Oil and Grease	mg/L	<5	<5	<5	<5	<5	<5
Filterable Reactive Phosphate	µg/L	<50	<50	<50	<50	<50	<50
Biological Oxygen Demand	mg/L	<2	<2	<2	3	3	<2